

Memo No:- 315

Date:- 18/03/2024

Subject : Bacteriological Examination Report of Water Sample

Sample Details		Date & Time
Sample ID:	YNR/04896/3/2024	
Sample Classification:	Departmental	Collected By
Sender:	Radaur PHESD	PAWAN KUMAR.9467076911
Location :-	TW-YNR-JATHLANA-I, Govt Sen.Sec.School	Collection Date
Latitude :-	30.017807	13/03/2024 at 12:57
Longitude :-	77.249390	Received at lab
		13/03/2024 at 13:58
		Tested at Lab
		18/03/2024

Test Result (As Per BIS 10500 :2012)				
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-


- The Results Given above are related to the sample as received and tested in YAMUNA NAGAR lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "POTABLE"



Neeraj Mehta,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY YAMUNA
NAGAR
email:-chemist.yamunanagar@gmail.com

-----End of Report-----.

Copy Attached

Sub Divisional Engineer-
Public Health Engg. S/Div
Radaur (Yamuna Nagar)